



Public Works Department

2190 Atlanta Road
Smyrna, Ga. 30080
(770)-431-2850
(678)-631-5443 Fax

CITY OF SMYRNA

WATER AND SANITARY SEWER AVAILABILITY

The City of Smyrna has determined that water is available to the proposed development. Water is located on the other side of Hamby Street and will require the developer to bore this street for water services.

Sanitary sewer is not available to the proposed development. The developer will be required to install a sanitary sewer main extension from Powder Springs Street to serve this development. Elevations are the responsibility of the developer.

This information is based on a plat for zoning 2764 Hamby Street, Smyrna Ga. 30080 by Craig Wrigley.

Sincerely,

A handwritten signature in blue ink, appearing to be "Scott Stokes", written over a series of diagonal lines.

Scott Stokes
Director Public Works