



COBB COUNTY WATER SYSTEM

Customer Services Facility
660 South Cobb Drive
Marietta, Georgia 30060-3105
770-423-1000
www.cobbwater.org

Stephen D. McCullers, P.E.
Director

Divisions
Business Services
Customer Services
Engineering & Records
Stormwater Management
System Maintenance
Water Protection

October 8, 2020

Michael Barlow, PE
558 Old Norcross Road, Suite 204
Lawrenceville, GA 30046

Re: Proposed self-storage facility
Land Lot 444, 17th District, +/- 3.29 acres
Nickajack Creek Basin, South Cobb WRF

To Whom It May Concern:

Current Cobb County policy is to provide wastewater treatment capacity for approved zonings. Therefore, we will be able to provide capacity for your approved zoning classification with the following stipulations as set forth by the Cobb County Board of Commissioners:

- The developer has 150 days from this date to present plans for review and approval. Water and sewer fees must be paid and construction started within 90 days after plan approval.
- Should you fail to meet this stipulation, this letter of allocation is invalid and you must reapply to this department for capacity. No preference will be given and your request will be placed at the bottom of the request list.
- This letter is only valid for the project referenced. It is non-renewable, non-transferable, non-extendible and does not guarantee that sewer lines are at the site. Upgrades to existing water distribution and wastewater collection facilities may be required of the Developer if the demands of this proposal exceed the capacity limits of our existing or proposed facilities.

There is a 16-inch water main on Atlanta Rd and an 8-inch water main on Daniell Dr available for use. A passing fire flow test will be required prior to approval of construction plans by this department.
Sincerely,

COBB COUNTY WATER SYSTEM

Chris Duggan
Christopher Duggan
Plan Review
Engineering & Records Division