



COBB COUNTY WATER SYSTEM

Customer Services Facility
660 South Cobb Drive
Marietta, Georgia 30060-3105
770-419-6200
www.cobbwater.org

Stephen D. McCullers, P.E.
Director

Divisions
Business Services
Customer Services
Engineering & Records
Stormwater Management
System Maintenance
Water Protection

April 9, 2019

Rob Anagnostis

Re: Proposed City of Smyrna Rezoning
(990 Pebblebrook Road)
0.9204+/- Acres
Land Lot 466, 17th District,
South Cobb Basin, South Cobb WRF

To Whom It May Concern:

Current Cobb County policy is to provide wastewater treatment capacity for approved zonings. CCWS will be able to provide capacity for your approved zoning classification with the following stipulations as set forth by the Cobb County Board of Commissioners:

→The developer has 150 days from this date to present plans for review and approval. Water and sewer fees must be paid and construction started within 90 days after plan approval.


→Should you fail to meet this stipulation, this letter of allocation is invalid and you must reapply to this department for capacity. No preference will be given and your request will be placed at the bottom of the request list.

→This letter is only valid for the project referenced. It is non-renewable, non-transferable, non-extendible and does not guarantee that sewer lines are at the site. Upgrades to existing water distribution and wastewater collection facilities may be required of the Developer if the demands of this proposal exceed the capacity limits of our existing or proposed facilities.

There is an existing 8-inch water main on Pebblebrook Road available for use. A passing fire flow test will be required prior to approval of construction plans by this department.

Sincerely,

COBB COUNTY WATER SYSTEM


Tim Davidson
Plan Review Engineer
Engineering & Records Division

cc: file