



CITY OF SMYRNA

2800 King Street / P.O. Box 1226, Smyrna, Georgia 30081

(770) 434-6600 / www.smyrnacity.com

CITY OF SMYRNA

WATER AND SEWER AVAILABILITY

The City of Smyrna has determined that water and sanitary sewer are available to the proposed development. Sanitary sewer is located within the northern right-of-way of Roswell Street and will require a dog house connection to the existing sewer main.

Water is located within the edge of road right-of-way of the northern side. This development will require two taps in order to circulate the water system.

This information is based upon a concept plan titled 1755 Roswell Street townhomes by Gaskins Engineering, dated 4/26/18.

Sincerely,

Scott Stokes
Director Public Works

MAYOR
A. MAX BACON

CITY COUNCIL

WARD 1
DEREK NORTON

WARD 2
ANDREA BLUSTEIN

WARD 3
TERI ANULEWICZ

WARD 4
CHARLES A. WELCH

WARD 5
SUSAN WILKINSON

WARD 6
DOUG STONER

WARD 7
RON FENNEL

CITY ADMINISTRATOR
MICHAEL L. JONES, P.E.

CITY CLERK
TERRI GRAHAM

CITY ATTORNEY
SCOTT A. COCHRAN

MUNICIPAL COURT JUDGE
E. ALTON CURTIS, JR.