

ORDINANCE 2022-06

AN ORDINANCE OF THE CITY OF SMYRNA, GEORGIA, PROVIDING FOR THE AMENDMENT OF THE CODE OF ORDINANCES OF THE CITY OF SMYRNA AS IT RELATES TO THE MINIMUM SIZE FOR CONTINUOUS COPPER TUBING IN SERVICE LINES

Amend Appendix D, Section 5 (i) – to increase the minimum size for continuous copper tubing from $\frac{3}{4}$ inch to 1 inch. to read as follows:

Appendix D, Section 5 (i) Service lines; All service lines shall be individual, one service per single-family structure, and a minimum of 1-inch type K continuous copper tubing. The water main shall be dry or wet tapped. All taps will be at 90 degrees from top center using a tapping saddle and tapped through a corporation stop. Approved manufactures for tapping saddles are JCM, Smith-Blair or Ford. Approved manufactures for curb and corporation stops are AY McDonald or Ford. Top taps shall not be allowed.

This ordinance is passed and duly adopted this 21th day of February, 2022.

The Honorable Derek Norton
Mayor, City of Smyrna, Georgia

ATTEST:

Heather Peacon-Corn
City Clerk, City of Smyrna, Georgia

Approved as to form:

Scott A. Cochran, City Attorney

CITY SEAL:

