

## **CITY OF SMYRNA**

### **WATER AND SEWER AVAILABILITY**

The City of Smyrna has determined that water and sewer are available to the proposed development. Water and Sewer are both located in Fleming Street. Existing water and sewer taps will be used where possible. Any new water and sewer taps are the responsibility of the developer. Elevations are the responsibility of the developer. Note there is a huge difference in elevations between the City GIS infrastructure and your survey. This information is based upon a project survey for 1084 Fleming Street by ACME American dated 08/05/14.