



COBB COUNTY WATER SYSTEM

Stephen D. McCullers, P.E.
Director

Customer Services Facility
660 South Cobb Drive
Marietta, Georgia 30060-3105
770-419-6200
www.cobbwater.org

February 28, 2019

Divisions
Business Services
Customer Services
Engineering & Records
Stormwater Management
System Maintenance
Water Protection

Kyle Sharpe, PE
LeCraw Engineering

**Re: Proposed 80-unit independent senior living
3.11 +/- Acres
Land Lot 606, 17th District
Nickajack Creek Basin, South Cobb WRF**

To Whom It May Concern:

Current Cobb County policy is to provide wastewater treatment capacity for approved zonings. Therefore, we will be able to provide capacity for your approved zoning classification with the following stipulations as set forth by the Cobb County Board of Commissioners:

→The developer has 150 days from this date to present plans for review and approval. Water and sewer fees must be paid and construction started within 90 days after plan approval.

→Should you fail to meet this stipulation, this letter of allocation is invalid and you must reapply to this department for capacity. No preference will be given and your request will be placed at the bottom of the request list.

→This letter is only valid for the project referenced. It is non-renewable, non-transferable, non-extendible and does not guarantee that sewer lines are at the site. Upgrades to existing water distribution and wastewater collection facilities may be required of the Developer if the demands of this proposal exceed the capacity limits of our existing or proposed facilities.

There is an existing 8-inch water main on East-West Connector available for use. A passing fire flow test will be required prior to approval of construction plans by this department.

Sincerely,

COBB COUNTY WATER SYSTEM

Tim Davidson
Plan Review
Engineering & Records Division

Cobb County...Expect the Best!
www.cobbcounty.org