

(h)

The fire prevention code is amended as follows:

*Sprinkler Requirements.* Use of sprinkler systems in multifamily structures and small commercial buildings .

1.

All new commercial buildings shall be sprinkled throughout with an approved automatic sprinkler system.

2.

Existing buildings, over 5,000 square feet shall have installed an approved automatic sprinkler system when one or more of the following conditions apply:

a.

b.

Change of usage.

c.

Additions to an existing building greater than 50 percent of area of building.

d.

e.

As required by other applicable codes.

3.

All sprinklered commercial buildings that currently have approved sprinkler systems must continue to maintain their systems in accordance with approved sprinkler plan.