



City of Smyrna

2800 King Street
Smyrna, GA 30080
770-434-6600
www.smyrnacity.com

Issue Sheet

File Number: 2020-234

Agenda Date: 6/29/2020

Version: 1

Status: ATS Review

In Control: Planning and Zoning Commission

File Type: Authorization

Agenda Number: C.

WARD / COUNCILMEMBER: Ward 3 / Councilmember Lindley

\$ IMPACT: N/A

Agenda Title:

Public Hearing - Plat Approval with Variances - V20-030 - 1.72 Acres - Land Lot 487 -
1151 Stephens Street - Longo Homes, Inc

ISSUE AND BACKGROUND:

The applicant is requesting approval to reconfigure three existing lots into three residential lots at 1151 Stephens St. The subject property is currently comprised of three lots of record; two fronting on Stephens St, and one landlocked with no street access. The three lots are within the Davis Subdivision. The lots are occupied by a single-family home that will be demolished. The applicant wishes to reconfigure the three lots all with frontage on Stephens St to build a single-family home on each lot. The applicant has submitted a proposed site plan for the development for your reference.

RECOMMENDATION / REQUESTED ACTION: Community Development has reviewed the proposed reconfiguration and replatting against the requirements of the R-15 zoning district. The variances are necessary to reconfigure the three lots and pull the proposed homes away from the existing stream buffer. The subject property will maintain an R-15 zoning classification and will not increase the density for the property in its current configuration. Community Development recommends **approval** of the requested reconfiguration and replatting of 1151 Stephens Street with the following conditions:

1.The development shall have the following setbacks:

- Front - 25 feet
- Side - 10 feet
- Rear - 30 feet
- Driveway setback - 2 feet

2.The development shall have a minimum lot width of 63 feet.

3.The storm water detention plan shall be designed to create at least a 10% reduction in a 2-year to 100-year storm event. The City Engineer shall approve all plans.

4.The developer shall dedicate 5 feet of Right-of-Way along Stephens Street.

5.Approval of the subject property for plat approval shall be conditioned upon the development of the property in substantial compliance with the site plan submitted 6/12/2020 created by Gaddy Surveying &

Design, Inc. and all zoning stipulations above.